



Product Service

EC-Attestation of Conformity

No. E8 05 03 54505 009

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4
JANGAN-DONG, DONG DAE MUN-GU
130-104 SEOUL
KOREA**Name of Object:** Industrial, Scientific and Medical
equipment
Compact Beam Switch

This EC-Attestation of Conformity is issued according to the Directive 89/336/EEC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed equipment complies with the principal protection requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: SKTCEE-050318-034**Date,** 2005-03-21

After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

**EC-Attestation of Conformity**

No. E8 05 03 54505 009

Model(s): KPS-CTV, KPS-CTVP,
KPS-CTH, KPS-CTHP

Description of Object: Rated input voltage: 12-24 V d.c.
Rated input current: 40 mA max.

Tested according to: EN 60947-5-2:1998+A1:1999