



Product Service

# EC-Attestation of Conformity

No. N8 06 06 54505 024

**Holder of Certificate:** KUN HUNG ELECTRIC CO., LTD.

113-4, Jangan-Dong, Dongdaemoon-Gu  
130-100 SEOUL  
KOREA

**Product:** Limit Switches  
(Limit switch)

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 73/23/EEC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0113806



**Date,** 2006-06-28



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



**EC-Attestation of Conformity**

**No. N8 06 06 54505 024**

**Model(s):** KH-8005-S, KH-8005-C, KH-8005-R,  
KH-8005-P, KH-8005-PR, KH-8005-CPR,  
KH-8005-SR

**Parameters:**

Rated input voltage/current/ utilization category:	125 V a.c./5 A/AC-12 125 V a.c./3 A/AC-15 250 V a.c./5 A/AC-12 250 V a.c./2 A/AC-15 125 V d.c./0.4 A/DC-12 125 V d.c./0.1 A/DC-14 250 V a.c./d.c.
Rated insulation voltage:	2.5 kV
Rated impulse withstand voltage:	IP55
Degree of protection:	3
Pollution degree:	II
Overvoltage category:	Single-Pole(Same polarity)
Number of polarity:	100000 (electrical)
Number of operating cycles:	1000000 (mechanical)

**Remark:**  
When installing/inserting the equipment  
all requirements of the mentioned test standards  
must be fulfilled.

**Tested according to:** EN 60947-1:2004  
EN 60947-5-1:2004