



Product Service

Attestation of Conformity

No. N8 11 05 54505 054

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4, Jangan-Dong, Dongdaemoon-Gu
SEOUL 130-100
REPUBLIC OF KOREA**Product: Emergency switch off
(Emergency Stop Switch)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0113641**Date,** 2011-05-16
(James Jeon)

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 11 05 54505 054

Model(s): **KEPB 160 ER x-y**
x. Switch symbol marking method
Blank: No color
S: White
y. Contact Arrangement
1a: a contact one
2a: a contact two
1b: b contact one
2b: b contact two
1a1b: a contact b contact

Parameters:

Rated input voltage:	125/250 V a.c.
Rated input current:	3 A
Rated insulation voltage:	250 V a.c./d.c
Rated impulse withstand voltage:	4 kV
Utilization category:	AC-15
Degree of protection:	IP65
Pollution degree:	3
Overvoltage category:	III
Number of operating cycles:	100000 (electrical) 150000 (mechanical)
Rated Conditional short-circuit current:	1 KA
Remark:	When installing/inserting the equipment all requirements of the mentioned test standards must be fulfilled.

Tested according to: EN 60947-1:2007
EN 60947-5-1:2009
EN 60947-5-5/A1:2005