

CERTIFICATE OF COMPLIANCE

Certificate Number 20170818-E487989
Report Reference E487989-20170814
Issue Date 2017-AUGUST-18

Issued to: KUN HUNG ELECTRIC CO LTD
183 Hancheon-ro Dongdaemun-gu
Seoul 130-836 KOREA

**This is to certify that
representative samples of**

EMERGENCY STOP DEVICES
Series KSE Emergency Stop. Cat. No. KSE followed by
P or B, followed by -22, -25 or -30, followed by 4 or 6,
followed by 1C, 2C, 3C, 1A or 2A, followed by 0, 1 or 2,
followed by 1, 2, 3 or 4.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 508, Industrial Control Equipment
IEC 60947-5-5, Low-voltage Switchgear and Controlgear
part 5-5 for Control circuit devices and switching elements -
electrical emergency stop device with mechanical latching
function
CAN/CSA C22.2 No. 14-13, Industrial Control Equipment

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

